



**Housing Authority of the County of Merced**

405 U STREET MERCED, CA 95341  
PHONE (209) 722-3501 TDD 711 or 800-855-7100  
[www.merced-pha.com](http://www.merced-pha.com)

**IFB #2021-02: Public Housing Unit Modification**

**ADDENDUM #5**

April 7, 2021

Question (Q) and Answer (A):

1. Q: Will the tubs that are already installed at the 2 ADA specified units need to be removed?

A: Yes, the tub/showers at the 2 specified ADA units will need to be removed in order for the ADA compliant roll-in showers to be installed.

2. Q: When the bathtub faucets get replaced, will temp valves need to be installed since these are older units and they might not have them?

A: The Authority last modernized the Livingston units in 1993 and the Los Banos units were modernized in 1996, however it is unknown if they currently have temp valves in them. Refer to page 7, number 7 of the scope of work for the Authority's specifications regarding what the existing faucets should be replaced with. If any parts of the wall are needed to be removed, please refer to page 7, number 4 of the scope of work.

**END OF ADDENDUM #5**