



**Housing Authority of the County of Merced**

405 U STREET MERCED, CA 95341  
PHONE (209) 722-3501 TDD 711 or 800-855-7100  
[www.merced-pha.com](http://www.merced-pha.com)

---

**RFP #2019-06: HVAC/Roofs/Window Replacement  
Phase II**

**ADDENDUM #1**

March 22, 2019

1. The new bathroom windows are to be framed type. New frames will be tight to existing exterior window frames.
2. New Ground Fault Circuit Interrupter (GFCI) circuits are to be installed on the roof for HVAC units. Existing roof outlets are non-grounded. Contractor to properly install new GFCI circuits per code.
3. There are areas of dryrot on soffit that have been temporarily covered on the underside of exposed areas. The covers are to be removed during demolition and dryrot will be properly repaired. This cost will be included on the Request for Sealed Proposal Form (Proposal Packet, Attachment #4), Additional Cost Items, "Soffit" line.

**END OF ADDENDUM #1**

