

Housing Authority of The County of Merced

405 U STREET MERCED, CA 95341

PHONE (209) 722-3501 * FAX (209) 386-4187

VISIT OUR WEB SITE AT: www.merced-pha.com



IFP #2016-14: ADA Compliance Modifications Merced Migrant

ADDENDUM #1

November 30, 2016

1. PULL STATION ALARM:
 - a) The pull station alarm will be a strobe light fire alarm that activates when the other alarms go off.
 - b) Alarm may be connected to/tied into an existing fire panel (Notifier® AFP-200).
2. Profit and overhead amounts are expected to be approximately 7-8% each.

END OF ADDENDUM #1